



IL-FONDAZZJONI TAL-KONKATIDRAL TA' SAN GWANN
THE ST JOHN'S CO-CATHEDRAL FOUNDATION

Our Ref: C00410_WPD1_Clarification 01

23rd October 2018

Re: STJCF006/18 – WPD1 – Tender for the Supply of Light Fittings for the 'Caravaggio Centre'

Clarification 01

Following the Clarification Meeting held on the 15th October 2018 which started at 09:00AM and was concluded at 10:00AM, all prospective bidders are to note the following queries and their respective clarifications:


Ref	Query	Reply
A-01	Kindly clarify, in general, the technical design intent behind the battery packs for all light fittings?	Where possible, the required battery packs shall be integrated into the light fitting. If this is not possible, they shall be positioned a maximum of 2m away for the light fitting in question.
A-02	Kindly clarify whether or not light fittings SP1/SP2 are to be track mounted or not.	The light fittings with reference SP1/SP2 will <u>not</u> be track mounted. These shall be wall mounted at high level.
A-03	Kindly clarify if there is scope to reduce the IP rating of light fitting CM1/CM1Em.	Yes, an IP rating of IP65 for the light fittings CM1/CM1Em is being deemed acceptable.
A-04	Clarify the integration between the BMS / DALI system / emergency lighting.	All references to BMS in the specification are to refer to LMS (Lighting Management System), in this particular application the LMS shall be DALI based and shall be designed in accordance to the zones and grouping.

Kindly also note a revised BOQ has been issued including a new line item with reference 2.2 [Central DALI control system inclusive of all programming, wiring by others.]

Further to the above, kindly note that the deadline for submission of the tender is being extended to Friday 2nd November 2018 by 1200Hrs.

Cynthia de Giorgio

Obo: St John's Co-Cathedral Foundation



TRIQ SAN GWANN, VALLETTA VLT 1156, MALTA
TEL: +356 2122 0536 FAX: +356 2123 3623